



aitex[®]
research & innovation center

REACTION TO FIRE

Applicant:

ROPRE, LDA

PARQUE INDUSTRIAL DO CANHOSORUA M , LOTE 19
PT-6200-027 COVILHA

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN2737.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN2737

The sample referenced as:

"231 IGN, 231 IGN V , R´BULL PRO 10"

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

7th of November 2025



Date: 07/11/2025 14:27:14

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño
Head of Fire Behaviour lab.